

Supplemental Questions for Fire Alarms:

- Is this a high-rise building and/or campus project? _____ (Yes or No)
- Is a Battery Test required (Always for Complete, Normally for T.I.) _____ (Yes or No)
- What is the total number of devices being added or modified? _____ Quantity
 - *A “device” shall be defined as any initiating device, notification appliance, control panel or sub-panel including, but not limited to the following: heat detector; smoke detector; beam detector; gas detector; flame detector; spot-type detector; manual fire alarm box (pull station); supervisory (tamper) switch (e.g., monitor module); waterflow switch (e.g. monitor module); bell; horn strobe; combination horn/strobe; speaker; monitor; printer, control module, relay module, etc. This shall not include any of the devices or equipment specifically identified as having their own custom fees associated with them such as: fan coils, dampers, magnetic hold-opens, batteries, hi/lo air pressure switches, hi/lo temperature switches, hi/lo water level indicators, graphic annunciators, or specialty detection devices.*
- What is the total number of dampers being controlled? _____ Quantity
- How many high/low air pressure alarms are there? _____ Quantity
- How many graphic annunciator panels are there? _____ Quantity
- What is the total number of fan coils being controlled? _____ Quantity
- What is the total number of magnetic door hold-opens being added/modified? _____ Quantity
- How many low air/ low water/ high/low temperature alarms are there? _____ Quantity
- Any ancillary equipment – Other _____ Quantity