

Standpipe and Hose Systems

General Information

Date: _____ Inspector: _____ System: _____

Location: _____

General

System designation _____

Building _____

Location of control valve _____

Type of system Class I Class II Class III

Length of hose provided None 50 ft (15 m) 75 ft (23 m) 100 ft (30 m)

Type of hose Rubber lined Unlined

(If unlined hose is presently installed, it may remain in use. However, when it requires replacement only lines hose should be used in accordance with NFPA 14.)

Are shutoff nozzles provided? Yes No

(If “no” nozzles should be replaced with shutoff type in accordance with NFPA 14.)

Are pressure regulating devices provided? Yes No

Type of regulating device _____

Valves

How are valves supervised? Seated Locked Tamper switch

Are valves identified with signs? Yes No

Water Supply (See Chapters 7 and 9 of NFPA 25)

When was last water supply test made? _____

Are reservoirs, tanks, or pressure tanks in good condition? Yes No

Pumps (See Chapter 8 of NFPA 25)

Is fire pump Diesel Electric Gasoline None?

Is pump in good condition? Yes No

When was pump last tested? _____

Fire Department Connections

Location _____

Are identification signs provided? Yes No

Notes