

Foam-Water Sprinkler Systems Quarterly Inspection

This form covers a 1-year period.

Year: _____ System: _____

Location: _____

Y = Satisfactory

N = Unsatisfactory (explain below)

Date:			
Inspector:	Y	N	Notes
Inspect foam concentrate strainers.	<input type="checkbox"/>	<input type="checkbox"/>	
Inspect area beneath and surrounding foam system to assure adequate drainage.	<input type="checkbox"/>	<input type="checkbox"/>	
Inspect system piping and fittings for corrosion, misalignment, trapped sections, low-point drains, condition of rubber-gasketed fittings.	<input type="checkbox"/>	<input type="checkbox"/>	
Inspect hangers and supports for damaged or missing parts, secure attachment to structural supports and piping, rust, corrosion, and missing or damaged protective coatings.	<input type="checkbox"/>	<input type="checkbox"/>	
Additional Notes:			