

# Foam-Water Sprinkler Systems Annual Inspection

Date: \_\_\_\_\_ Inspector: \_\_\_\_\_ System: \_\_\_\_\_

Location: \_\_\_\_\_

Y = Satisfactory

N = Unsatisfactory (explain below)

	Y	N	Notes
<b>Foam Water Sprinklers</b> Assure they are free of corrosion, obstruction, foreign materials, and physical damage.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Sprinkler Piping</b> Assure it is in good condition, free of damage, not corroded, not misaligned, and not subject to external leaks.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Pipe Hangers and Seismic Braces</b> Assure they are neither damaged nor corroded.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Gauges</b> Assure they are in good condition and normal water pressures are maintained.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Additional Notes:</b>          			