

Foam-Water Sprinkler Systems Annual Maintenance

Date: _____ Inspector: _____ System: _____

Location: _____

Y = Satisfactory

N = Unsatisfactory (explain below)

	Y	N	Notes
Exercise Valves Operate each control valve through its full range and return it to its normal position. Reseal or relock valves as appropriate.	<input type="checkbox"/>	<input type="checkbox"/>	
Lubricate Valves Lubricate all valves with graphite or a mixture of light oil and graphite.	<input type="checkbox"/>	<input type="checkbox"/>	
Additional Notes: 			